



Honeywell

Security Products Dealer

June 19, 2025

*****FIRE ALARM CERTIFICATION*****

Twenty-One Riverside Condo
21 Riverside Dr.
Cocoa, FL 32922

This is to certify that ATP has a contract for monitoring a Fire Alarm System at the location indicated above. The System provides Fire Protection for the entire building with the following features:

1. THE FIRE ALARM IS MONITORED BY Affiliated MONITORING @ 844-811-82617

For:

1. Fire alarm
2. System Trouble
3. Supervisory

*Local audible alarm is provided


2. The building has a sprinkler system which is monitored by the Fire Alarm System in accordance with NFPA Standards.

The building contains a wet pipe fire sprinkler system that was designed and installed by unknown contractor.

The wet pipe fire sprinkler system appears to be designed per NFPA 13 for common areas and NFPA 13R for dwelling units.

Dwelling Units contain fire sprinkler heads in living area and bedrooms; bathrooms greater than 55 sq. ft. and closets that exceed 24sqft.

ATP Fire performs its fire sprinkler inspections in accordance with NFPA 25 which does not allow fire sprinkler contractor (ATP) to verify current fire sprinkler system code compliance.

SIGNED: _____ 

Certifying Agent: ATP
215 West Drive
Melbourne, FL 32904
321-729-6462

FrontLine Protection Systems, LLC and Frontline Fire Protection Systems, LLC
Subsidiaries of American Total Protection, LLC
215 West Dr., Melbourne, Florida 32904
Phone- 321.729.6462 Toll Free- 877.729.6462 Fax- 321.729.6353
EF#20001315 FPC14-000109 EF#20001338 www.atpalarms.com

